

Level 1 EPSS Weekly Inspection Checklist

Generator Number _____

Date completed _____

Completed by _____

Component to Inspect/Test	Action	Comments
<i>Fuel</i>		
Main supply tank level		
Day tank level		
Day tank float switch		
Supply or transfer pump operation		
Solenoid valve operation		
Water in fuel system		
Flexible fuel hoses and connectors		
<i>Lubrication System</i>		
Oil level		
Lube oil heater		
<i>Cooling System</i>		
Level		
Adequate cooling water to the heat exchanger		
Adequate fresh air through the radiator		
Water pump(s)		
Condition of flexible hoses and connection		
Jacket water heater		
<i>Exhaust System</i>		
Leakage		
Drain condensate traps		
<i>Battery System</i>		
Electrolyte levels		
<i>Electrical System</i>		
General inspection		
<i>Prime Mover and Generator</i>		
General inspection		
General condition of EPSS, any unusual condition		
Service room or housing housekeeping		
Verify system is in automatic mode		

Action Codes

- √ Inspected, no problems noted
- C Problem identified and corrected
- F Problem identified that could not be immediately corrected. Interim measures initiated as needed.
- NA Not Applicable