



Greater efficiency supports patient care.

ROOM VENTILATION SCHEDULE RE-ASSESSMENT

All ECM content was independently developed and reviewed to be vendor-, product-, and service provider-neutral.

DESCRIPTION

Save energy, money, and increase occupant comfort with a Room Ventilation Re-assessment (RVR) of your facility. Thoroughly re-evaluating ventilation and minimum airflow requirements space-by-space can yield savings in Air Handling Unit (AHU) fan, cooling and heating energy, while ensuring adherence to code and standard requirements.

PROJECT TALKING POINTS

- A room ventilation schedule (RVS), usually generated during the design phase of a project, specifies the amount of supply and outdoor air provided as well as the amount of return and exhaust air extracted from each space. Ventilation and airflow should be determined as a function of the room type, area, ceiling height, and relevant ASHRAE standard, among other factors.
- Space types in a facility change over time, and ventilation and airflow rates may no longer be relevant or code compliant with the most recently adopted code. An RVR addresses this issue by re-setting rates to be current code compliant and generates a new RVS as an output.
- Zone terminal unit (TU) flows are re-evaluated from the new RVS data providing an opportunity to identify under or over-performing areas. This generally results in reduced airflows at the AHU serving the TUs.
- Often, building ventilation and airflow rates have been set to a flat percentage of design airflow rather than taking into consideration the needs of the specific space. This is especially common in non-critical spaces such as administrative offices, waiting lobbies, and staff lounges. This leads to the overuse of energy and patient comfort issues.
- Know how your system operates- the requirements for a system with a constant volume (CV) TU are different from a variable-air-volume (VAV) TU.

TRIPLE BOTTOM LINE BENEFITS

Cost Benefits: Reducing fan, heating, and cooling energy reduces overall energy costs.

Environmental Benefits: Reducing energy consumption also has associated emissions reductions and positive environmental impacts.

Societal Benefits: Occupant comfort is increased through RVS efforts, and the money saved can be redirected into enhanced patient care.

PURCHASING CONSIDERATIONS

- If your air handler does not have variable frequency drives (VFDs), consider installing them prior to implementation of an RVS re-assessment. Full savings potential of this process will not be realized without drives.
- Ease of access to your dampers. For example, if you have a constant volume (CV) TU, flow adjustments will likely occur at the damper, and ease of access is important to keep costs low.

HOW-TO

1. Establish a group of key stakeholders, including Facility managers, mechanical engineers, facilities staff, floor supervisors, building automation system (BAS) vendor, and any external consultants.
2. Collect drawings for the facility, and ensure, at a minimum, the following are included:
 - Any planned renovation, addition or retrofit drawings
 - Any renovation, addition, or retrofit drawings that have already occurred
 - Architectural drawings, including reflected ceiling plans
 - As-builts
 - Life safety drawings
 - Mechanical drawings for all parts of the facility
 - BAS setpoints and trend data for TUs (when available)
3. Extract relevant data from these plans and associate each space with an Air Handling Unit (AHU). The spreadsheet should also capture the following:
 - Room number (unique identifier)
 - Room name (for easy classification)
 - Terminal unit (TU) associated with the space (please note: this could be a variable-air-volume (VAV) box, a constant volume (CV) box, a reheat coil, etc.)
 - Space supply, return and exhaust airflow (either from the existing HVAC drawings or, preferably, from BAS data)
 - Square footage
 - Ceiling height
 - Space occupancy (if readily available)
 - Number of diffusers (if clear)
4. Once this data is amassed, classify by appropriate space type. For healthcare specific spaces, use [ANSI/ ASHRAE/ ASHE 170-Ventilation of Healthcare Facilities](#). For non-healthcare specific spaces, such as offices or staff breakrooms, use [ASHRAE 62.1-Ventilation for Acceptable Indoor Air Quality \(note: always use the most recent version available\)](#).

5. After rooms are classified, use relevant ASHRAE ventilation tables to determine appropriate ventilation and airflow levels versus actual. This allows for a calculation of potential energy savings.
6. Using this information and the calculation methodology in ASHRAE 62.1, develop a new code-compliant list of airflow and ventilation levels.
7. Give this list to the facilities staff to implement. Coordinate with floor managers as necessary for manual adjustments and inspections, and with the BAS vendor for VAV TU setpoint changes.
8. Be mindful of the pressure relationships in spaces as well, as well as the overall pressure of the facility. For example, isolation rooms should have a negative pressurization, while protective environment rooms are expected to be positively pressurized.
9. Test the performance of the system post-implementation, and measure and verify (M&V) your energy use after implementation.
 - Don't forget to see if a project such as RVS adjustment qualifies for a rebate in your area. Before project implementation, seek pre-approval from your local rebate program, if available.

REGULATIONS, CODES AND STANDARDS, POLICIES

ANSI/ ASHRAE Standard 62.1- [Ventilation for Acceptable Indoor Air Quality](#)

ANSI/ ASHRAE/ ASHE Standard 170- [Ventilation of Healthcare Facilities](#)

CROSS REFERENCES

[LEED v4. For BD + C: Healthcare](#)

- Energy and Atmosphere
 - Prerequisite- Fundamental Commissioning and Verification
 - Prerequisite-Minimum Energy Performance
 - Credit- Enhanced Commissioning
 - Credit- Optimize Energy Performance
- Indoor Environmental Quality
 - Prerequisite- Minimum Indoor Air Quality Performance
 - Credit- Thermal Comfort

RESOURCES

Courses:

ASHRAE- Designing and Operating High-Performing Healthcare HVAC Systems (3 Hour Course)- <https://www.ashrae.org/professional-development/all-instructor-led-training/instructor-led-training-seminar-and-short-courses/designing-and-operating-high-performing-healthcare-hvac-systems>

ASHRAE- Healthcare Facilities: Best Practices for HVAC Design and Operation (6 Hour Course)- <https://www.ashrae.org/professional-development/all-instructor-led-training/instructor-led-training-seminar-and-short-courses/healthcare-facilities-best-practices-for-hvac-design-and-operation>

References:

HVAC Design Manual for Hospitals and Clinics, 2nd Edition- <https://www.ashrae.org/technical-resources/bookstore/health-care-facilities-resources>

©2023 The American Society for Health Care Engineering (ASHE) of the American Hospital Association

Disclaimer: The information provided may not apply to a reader's specific situation and is not a substitute for application of the reader's own independent judgment or the advice of a competent professional. ASHE does not make any guaranty or warranty as to the accuracy or completeness of any information contained in this document. ASHE and the authors disclaim liability for personal injury, property damage, or other damages of any kind, whether special, indirect, consequential, or compensatory, that may result directly or indirectly from use of or reliance on this document.

ALL RIGHTS RESERVED. No part of the presented material may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, recording, or by any information storage and retrieval system, without permission in writing from the publisher.