



Greater efficiency supports patient care.

Evaluate steam traps for repair or replacement.

All ECM content was independently developed and reviewed to be vendor-, product-, and service provider-neutral.

Description

Inspect and repair steam traps to maintain efficient steam system operation. Evaluate existing steam traps and identify opportunities for replacing equipment.

- **Project Talking Points**

- Steam traps in closed-loop steam systems regulate the flow of steam and prevent live steam from passing into the condensate return system. When traps fail, live steam migrates into the condensate system, overheating condensate piping and allowing steam to be lost through atmospheric vents.
- Preventing steam leaks will enhance both water and energy efficiency, improve heating system reliability, and increase life expectancy of equipment. Occupant thermal comfort is safeguarded when a stable boiler operating pressure is maintained.
- [According to the U.S. Department of Energy, leaks in steam traps cause the loss of up to 20 percent of the steam generated by a typical boiler. Losses can vary widely.](#)
- Steam traps can fail over time, so assessment and repair are regular preventative maintenance tasks. According to the [U.S. Department of Energy](#), low-pressure (<30 psig) steam systems should have traps checked annually.

Triple Bottom Line Benefits

- **Cost benefits:** Reduced water, chemical, sewer, and energy costs due to reduced water consumption and reduced water heating associated with leaks. (See case studies for specific examples.) A more reliable steam system also decreases reactive maintenance, allowing for better use of FTE resources.
- **Environmental benefits:** Reducing energy use and associated emissions (connected to treating, supplying, and heating potable water) always has an environmental benefit. Further, reductions in the amount of water used reduces chemical consumption for water treatment. Water conservation also protects the natural water cycle and decreases strain on the municipal water supply.
- **Health and safety benefits:** Improvements in safety and thermal management enhance patient and staff experience. Steam equipment operates more efficiently and requires

fewer urgent maintenance calls when traps are proactively maintained. Money saved as a result can be applied to the health care mission of the hospital.

Additional commissioning resources include:

- California Commissioning Collaborative
 - [California Commissioning Guide: Existing Buildings](#) (2006)
- Oak Ridge National Laboratory
 - [A Practical Guide for Commissioning Existing Buildings](#)
- U.S. Department of Energy, Energy Efficiency & Renewable Energy, Building Technologies Program
 - [Commissioning Existing Hospital Buildings Aids Peak Energy Performance](#)

Purchasing Considerations

- Add regular steam trap maintenance into the facility preventative maintenance plan. Either contract an external vendor or provide tools and education to complete inspections in-house.

How-To

1. Determine who's on the team: Commissioning agent (if applicable), building engineer, and HVAC maintenance personnel.
2. Perform a walk-through of the facility to document the location and type of all steam traps. Use a log to record the information gathered, including the following for each trap:
 - Location, noting ease of access for maintenance
 - Type of trap (mechanical, thermostatic, thermodynamic)
 - Identify current steam traps and evaluate upgrade opportunities based on changes in steam trap technology.
 - Whether assessment equipment has been permanently installed to monitor performance
 - Condition of steam trap. Inspect for corrosion, steam and other leaks.
3. Conduct a performance assessment using one of the following methods, as outlined in the U.S. Department of Energy document [Federal Technology Alert: Steam Trap Performance Assessment](#):
 - Sight method: Observe the fluid downstream of the trap after a discharge. "Flash" steam (a "lazy, billowy plume") will indicate the steam trap is functioning properly. "Live" steam (a "sharper, higher velocity plume") will indicate a trap failure.
 - Inspect condensate tank and "flash tank" vent discharges for steam plumes.

- Sound method (most reliable): Use a listening device to differentiate between the sound of normal operation and a trap failure.
 - Temperature method (least reliable): If the trap is significantly cooler than the temperature of the steam released by the boiler, it is likely flooded with condensate. If the temperature downstream of the trap is consistent with the temperature of the trap, this may indicate a steam leak as well.
 - To make this method more reliable, invest in or use a thermal imaging camera to evaluate the steam traps.
 - Conductivity method: A sensing chamber integrated into the steam trap, or just upstream of it, measures the difference between normal steam conductivity and conductivity in leak or blowout conditions.
4. If the trap has failed, identify whether it has failed in the open or closed position.

Typical steam trap failure modes:

- Float and thermostatic: Closed
 - Inverted bucket: Open or Closed
 - Bimetal thermostatic: Open
 - Impulse: Open
 - Thermodynamic disc: Open
5. Clean and repair all malfunctioning parts.
6. Document all steam trap maintenance activities in the steam trap log, and coordinate with Performance Improvement Measure *Practice preventive maintenance of major HVAC equipment*.

Tools

Please see the Dept of Energy [“Inspect and Repair Steam Traps”](#) energy tip for an example savings calculation.

Case Studies

[Nazareth Hospital](#) (Philadelphia, Pa.)

- Key Points
 - Conducted a comprehensive steam trap audit. Repaired or replaced faulty steam traps and sealed system leaks.
 - Retrofits and maintenance upgrades resulted in a 29-point improvement in ENERGY STAR score, culminating in ENERGY STAR certification.

U.S. Veterans Administration (VA) medical centers

- Key Points
 - A steam trap assessment was part of an integrated facility energy audit.
 - The assessment calculated both the steam trap performance level and the value of the lost steam. Malfunctioning traps were either repaired or replaced. Maintenance personnel were trained to perform ongoing monitoring and maintenance.
 - The retrofit was estimated to reduce steam losses by 50–75 percent.

Regulations, Codes and Standards, Policies

There are no regulatory requirements that require steam trap maintenance. If you have suggestions for related codes or regulatory compliance issues, please participate in the discussion below.

Cross References: LEED

- [LEED for Existing Buildings: Operations + Maintenance](#)
 - Energy & Atmosphere Prerequisite 1: Energy Efficiency Best Management Practices—Planning, Documentation, & Opportunity Assessment
 - Energy & Atmosphere Prerequisite 2: Minimum Energy Performance
 - Energy & Atmosphere Credit 1: Optimize Energy Efficiency Performance
 - Energy & Atmosphere Credit 2.1: Existing Building Commissioning—Investigation & Analysis
 - Energy & Atmosphere Credit 2.1: Existing Building Commissioning—Implementation
 - Energy & Atmosphere Credit 3.1: Performance Measurement—Building Automation System
 - Energy & Atmosphere Credit 5: Measurement & Verification
- [LEED for Healthcare: New Construction and Major Renovations](#)
 - Energy & Atmosphere Prerequisite 1: Fundamental Commissioning of Building Energy Systems
 - Energy & Atmosphere Prerequisite 2: Minimum Energy Efficiency Performance
 - Energy & Atmosphere Credit 1: Optimize Energy Efficiency Performance
 - Energy & Atmosphere Credit 3: Enhanced Commissioning
 - Energy & Atmosphere Credit 5: Measurement and Verification

ECM Synergies

[Establish baseline for current energy consumption.](#)

[Practice preventive maintenance of major HVAC equipment.](#)

More Resources

- ASHE (www.ashe.org)
 - [Healthcare Energy Guidebook](#)
 - Health Facility Commissioning Guidelines
- American Society of Heating, Refrigerating, and Air-Conditioning Engineers (www.ashrae.org)
 - [Guideline 14: Measurement of Energy and Demand Savings](#)
 - [Procedures for Commercial Building Energy Audits](#)
 - Level 1, Walk-Through Analysis
 - Level 2, Energy Audit, Energy Survey and Analysis. Provides guidance on how to tell when steam traps are functioning optimally.
 - [Service Life and Maintenance Cost Database](#). See chapters 2 and 4.
- U.S. Department of Energy, Energy Efficiency & Renewable Energy, Building Technologies Program
 - [Efficient Hospital Boilers Result in Financial, Environmental, and Safety Payoffs](#)
 - [Energy Smart Hospitals: Retrofitting Existing Facilities](#)
 - [Hospitals Realize Fast Paybacks from Retrofits and O&M Solutions](#)
 - [Hospitals Save Energy and Money by Optimizing HVAC Performance](#)

[Federal Technology Alert: Steam Trap Performance Assessment](#). This includes a detailed guideline for assessment methods and considerations. It contains cost and steam loss estimation tools.

ECM Descriptors

Energy, Water

Level: Beginner

Category List:

- HVAC
- Water

ECM Attributes:

- Optimize Operations
- Repair or Optimize Existing Systems (fix what you have)

Improvement Type:

- Maintenance

Department:

- Engineering/Facilities Management

©2023 The American Society for Health Care Engineering (ASHE) of the American Hospital Association

Disclaimer: The information provided may not apply to a reader's specific situation and is not a substitute for application of the reader's own independent judgment or the advice of a competent professional. ASHE does not make any guaranty or warranty as to the accuracy or completeness of any information contained in this document. ASHE and the authors disclaim liability for personal injury, property damage, or other damages of any kind, whether special, indirect, consequential, or compensatory, that may result directly or indirectly from use of or reliance on this document.

ALL RIGHTS RESERVED. No part of the presented material may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, recording, or by any information storage and retrieval system, without permission in writing from the publisher.